

Product certificate  
K92350/01



Issued 2016-04-01 Valid until Check website  
Replaces n.a.  
Page 1 of 2

## Alarm Transmission System (ATS)

### STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products/services supplied by

### Robert Bosch B.V.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K21030 "Alarm Transmission Systems (ATS)" dated 5 august 2014 for the following scope:

The supplier that delivers the equipment, network and tools for the end-to-end alarm transmission system and is responsible for the end-to-end performance and is responsible for compliance with the performance requirements and reporting based on proactive actions and provides the services "alarm communication system".

Luc Leroy  
Kiwa

Publication of the certificate is allowed.

Advice: consult [www.kiwa.nl](http://www.kiwa.nl) or [www.kiwafss.nl](http://www.kiwafss.nl) in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.  
Kiwa NCP  
Nevelgaarde 50  
Postbus 510  
3430 AM Nieuwegein

Tel. 088 99 83 055  
Fax 088 99 83 059  
Info.ncp@kiwa.nl  
www.kiwafss.nl

#### ATS Provider

Robert Bosch B.V. – Division  
Security Projects  
De Wel 22-24  
3871 MV Hoevelaken  
+31 (0)33 247 9187  
Email [info@nl.bosch.com](mailto:info@nl.bosch.com)

#### ATS Network

Specified per object certificate

Certification process consists of initial and regular assessment of:

- quality system
- product/service

### Alarm Transmission System (ATS)

---

#### Technical specification scope

For the delivery of the service alarm communication within an alarm transmission system, the following resources are needed:

- a. An approved and certified Supervised Premises Transceiver according to EN50136-2;
- b. An approved and certified Receiving Centre Transceiver according to EN50136-3 that is compatible with the Supervised Premises Transceiver;
- c. A network between the Supervised Premises Transceiver and Receiving Centre Transceiver as part of EN50136-1;
- d. A management organization that determines the performance the alarm transmission system and provides the periodic reporting provides EN50136-1 and, if necessary, directly communicates with the user;
- e. A management organization which takes proactive corrective actions if the performance of the alarm transmission system is insufficient.

---

#### Specific scope according to the certification scheme


Scope number 3. The supplier that delivers the equipment, network and tools for the end-to-end alarm transmission system and is responsible for the end-to-end performance and is responsible for compliance with the performance requirements and reporting based on proactive actions and provides the services "alarm communication system".

---

#### Application and use

The alarm transmission systems are to be used in conjunction with detection installations for fire according to EN54-1 and for intrusion according to EN50131-7 to ensure the life safety and / or security levels laid down in the basic design of these installations.

#### Marking



#### RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Robert Bosch B.V.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper methods.